NFRC Product Certification Authorization Report

Manufacturer: Elephant Windows and Doors Inc
Product Series: 152 Heavy Duty Lift/Slide Patio Door
Simulation Lab: SATI
Initial Cert. Date: 10/20/2025

Street: 16510 Los Gatos Almaden Rd
Product Type: DDSG
Sim. Report #: R9026.03-116-45 R1
Re-Certification Date:

City/State/Zip: Los Gatos, CA 95032
Air Leakage:
Sim. Report Date: 09/15/2025
Revised Date: 01/01/1970

Print Date: 12/24/2025
Test Date: 09/06/2025
Expiration Date: 09/06/2030

CPD Number: ELE-M-17 — **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00001-00001	XENE0185 / ARG / Clear (5mm/5mm) - 33mm IG	AT/AT	2	0.136(2)	0.870	TS-D	Fill 1: ARG (90)	N		CL	0.42	0.43	0.53	50
	00002-00001	XETN0187 / ARG / SB60 (6mm/6mm) - 33mm IG	AT/AT	2	0.094(2), 0.035(3)	0.790	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.31	0.46	51
	00003-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 33mm IG	AT/AT	3	0.136(2), 0.136(4)	0.350,0.350	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.34	0.36	0.46	51
	00004-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 33mm IG	AT/AT	3	0.136(2), 0.136(4)	0.350,0.350	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.36	0.32	0.40	51
	00004-00002	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 33mm IG	AT/AT	3	0.136(2), 0.136(4)	0.350,0.350	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.36	0.32	0.40	51
	00005-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.32	0.36	0.46	51
	00006-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.33	0.32	0.40	51
	00006-00002	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.33	0.32	0.40	51
	00007-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.136(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.34	0.45	51
	00008-00001	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.136(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.32	0.30	0.39	51
	00008-00002	XENE0185 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.136(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.32	0.30	0.39	51
	00009-00001	CEV11 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.05(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.17	0.28	51
	00010-00001	CEV11 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.05(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.32	0.16	0.24	51
	00010-00002	CEV11 / ARG / XENE0185 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.05(2), 0.136(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.32	0.16	0.24	51
	00011-00001	SB60 / ARG / PlanibelG (6mm/6mm) - 33mm IG	AT/AT	2	0.035(2), 0.168(3)	0.790	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.27	0.44	51
	00012-00001	SB60 / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 39mm IG	AT/AT	3	0.035(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.24	0.43	51

NFRC Product Certification Authorization Report

Manufacturer: Elephant Windows and Doors Inc
Street: 16510 Los Gatos Almaden Rd
City/State/Zip: Los Gatos, CA 95032
Print Date: 12/24/2025

Product Series: 152 Heavy Duty Lift/Slide Patio Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SATI
Sim. Report #: R9026.03-116-45 R1
Sim. Report Date: 09/15/2025
Test Date: 09/06/2025

Initial Cert. Date: 10/20/2025
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 09/06/2030

CPD Number: ELE-M-17 — **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00013-00001	SB60 / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 39mm IG	AT/AT	3	0.035(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.21	0.37	51
	00013-00002	SB60 / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 39mm IG	AT/AT	3	0.035(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.21	0.37	51
	00014-00001	WT172 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.034(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.19	0.39	51
	00015-00001	WT172 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.034(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.17	0.33	51
	00015-00002	WT172 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.034(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.17	0.33	51
	00016-00001	SB60-Lami / ARG / SB60 (5mm| 090SGP|5mm/5mm) - 39mm IG	AT/AT	2	0.035(2), 0.035(3)	0.870	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.25	0.42	50
	00017-00001	SB70-Lami / ARG / SB70 (6mm| 060SGP|6mm/6mm) - 39mm IG	AT/AT	2	0.035(2), 0.018(3)	0.790	TS-D	Fill 1: ARG (90)	N		CL	0.38	0.22	0.39	50
	00018-00001	S116 / ARG / S116 (5mm/5mm) - 33mm IG	AT/AT	2	0.076(2), 0.076(3)	0.870	TS-D	Fill 1: ARG (90)	N		CL	0.40	0.37	0.53	51
	00019-00001	XENE0185 / ARG / S116 / ARG / XENE0185 (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.076(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.34	0.45	51
	00020-00001	XENE0185 / ARG / S116 / ARG / XENE0185 (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.076(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.32	0.30	0.39	51
	00020-00002	XENE0185 / ARG / S116 / ARG / XENE0185 (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.136(2), 0.076(4), 0.136(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.32	0.30	0.39	51
	00021-00001	XDTN0180 / ARG / XDTN0180 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.042(2), 0.042(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.30	0.21	0.37	51
	00022-00001	XDTN0180 / ARG / XDTN0180 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.042(2), 0.042(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.19	0.32	51
	00022-00002	XDTN0180 / ARG / XDTN0180 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.042(2), 0.042(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.19	0.32	51
	00023-00001	XETN0187 / ARG / XETN0187 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.094(2), 0.094(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.32	0.44	51
	00024-00001	XETN0187 / ARG / XETN0187 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.094(2), 0.094(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.32	0.28	0.38	51
	00024-00002	XETN0187 / ARG / XETN0187 / ARG / Clear (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.094(2), 0.094(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.32	0.28	0.38	51

NFRC Product Certification Authorization Report

Manufacturer: Elephant Windows and Doors Inc
Product Series: 152 Heavy Duty Lift/Slide Patio Door
Simulation Lab: SATI
Initial Cert. Date: 10/20/2025

Street: 16510 Los Gatos Almaden Rd
Product Type: DDSG
Sim. Report #: R9026.03-116-45 R1
Re-Certification Date:

City/State/Zip: Los Gatos, CA 95032
Air Leakage:
Sim. Report Date: 09/15/2025
Revised Date: 01/01/1970

Print Date: 12/24/2025
Test Date: 09/06/2025
Expiration Date: 09/06/2030

CPD Number: ELE-M-17 — **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00025-00001	WT172 / ARG / WT172 / ARG / PlanibelG (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.034(2), 0.034(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.30	0.16	0.28	51
	00026-00001	WT172 / ARG / WT172 / ARG / PlanibelG (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.034(2), 0.034(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.15	0.25	51
	00026-00002	WT172 / ARG / WT172 / ARG / PlanibelG (6mm/6mm/6mm) - 42mm IG	AT/AT	3	0.034(2), 0.034(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.15	0.25	51
	00027-00001	WT172 / ARG / S116 / ARG / PlanibelG (6mm/5mm/6mm) - 40mm IG	AT/AT	3	0.034(2), 0.076(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.30	0.19	0.35	51
	00028-00001	WT172 / ARG / S116 / ARG / PlanibelG (6mm/5mm/6mm) - 40mm IG	AT/AT	3	0.034(2), 0.076(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.17	0.31	51
	00028-00002	WT172 / ARG / S116 / ARG / PlanibelG (6mm/5mm/6mm) - 40mm IG	AT/AT	3	0.034(2), 0.076(4), 0.168(5)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.17	0.31	51
	00029-00001	SDF178 / ARG / PlanibelG-Lami (6mm/6mm|060SGP|6mm) - 33mm IG	AT/AT	2	0.052(2), 0.168(3)	0.550	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.26	0.42	51
	00030-00001	SDF178 / ARG / PlanibelG-Lami (6mm/6mm|060SGP|6mm) - 33mm IG	AT/AT	2	0.052(2), 0.168(3)	0.550	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.39	0.23	0.36	51
	00030-00002	SDF178 / ARG / PlanibelG-Lami (6mm/6mm|060SGP|6mm) - 33mm IG	AT/AT	2	0.052(2), 0.168(3)	0.550	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.39	0.23	0.36	51
	00031-00001	S116 / ARG / Clear (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.40	0.39	0.54	50
	00032-00001	S116 / ARG / Clear (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.42	0.35	0.47	50
	00032-00002	S116 / ARG / Clear (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.42	0.35	0.47	50
	00033-00001	S116 / ARG / YEA (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.40	0.38	0.50	51
	00034-00001	S116 / ARG / YEA (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.42	0.33	0.43	51
	00034-00002	S116 / ARG / YEA (5mm/5mm) - 22mm IG	AT/AT	2	0.076(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.42	0.33	0.43	51
	00035-00001	PDE59B / ARG / Clear (6mm/6mm) - 24mm IG	AT/AT	2	0.04(2)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.20	0.35	51
	00036-00001	PDE59B / ARG / Clear (6mm/6mm) - 24mm IG	AT/AT	2	0.04(2)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.41	0.18	0.30	51

NFRC Product Certification Authorization Report

Manufacturer: Elephant Windows and Doors Inc
Street: 16510 Los Gatos Almaden Rd
City/State/Zip: Los Gatos, CA 95032
Print Date: 12/24/2025

Product Series: 152 Heavy Duty Lift/Slide Patio Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SATI
Sim. Report #: R9026.03-116-45 R1
Sim. Report Date: 09/15/2025
Test Date: 09/06/2025

Initial Cert. Date: 10/20/2025
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 09/06/2030

CPD Number: ELE-M-17 | **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00036-00002	PDE59B / ARG / Clear (6mm/6mm) - 24mm IG	AT/AT	2	0.04(2)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.41	0.18	0.30	51
	00037-00001	PDE59B / ARG / YEA (6mm/5mm) - 23mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.39	0.20	0.32	51
	00038-00001	PDE59B / ARG / YEA (6mm/5mm) - 23mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.41	0.18	0.28	51
	00038-00002	PDE59B / ARG / YEA (6mm/5mm) - 23mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.41	0.18	0.28	51
	00039-00001	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.33	0.48	51
	00040-00001	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.32	0.29	0.41	51
	00040-00002	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 39mm IG	AT/AT	3	0.076(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.32	0.29	0.41	51
	00041-00001	PDE59B / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 40mm IG	AT/AT	3	0.04(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.31	0.18	0.31	51
	00042-00001	PDE59B / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 40mm IG	AT/AT	3	0.04(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.31	0.16	0.27	51
	00042-00002	PDE59B / ARG / S116 / ARG / Clear (6mm/5mm/5mm) - 40mm IG	AT/AT	3	0.04(2), 0.076(4)	0.470,0.470	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.31	0.16	0.27	51
	00043-00001	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.30	0.33	0.48	50
	00043-00002	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.30	0.29	0.41	50
	00043-00003	S116 / ARG / S116 / ARG / Clear (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.30	0.29	0.41	50
	00044-00001	S116 / ARG / S116 / ARG / YEA (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4), 0.147(5)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.30	0.32	0.44	50
	00044-00002	S116 / ARG / S116 / ARG / YEA (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4), 0.147(5)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.30	0.28	0.38	50
	00044-00003	S116 / ARG / S116 / ARG / YEA (5mm/5mm/5mm) - 47mm IG	AT/AT	3	0.076(2), 0.076(4), 0.147(5)	0.630,0.630	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.30	0.28	0.38	50
	00045-00001	DoubleI / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.036(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.38	0.26	0.43	51

NFRC Product Certification Authorization Report

Manufacturer: Elephant Windows and Doors Inc
Product Series: 152 Heavy Duty Lift/Slide Patio Door
Simulation Lab: SATI
Initial Cert. Date: 10/20/2025

Street: 16510 Los Gatos Almaden Rd
Product Type: DDSG
Sim. Report #: R9026.03-116-45 R1
Re-Certification Date:

City/State/Zip: Los Gatos, CA 95032
Air Leakage:
Sim. Report Date: 09/15/2025
Revised Date: 01/01/1970

Print Date: 12/24/2025
Test Date: 09/06/2025
Expiration Date: 09/06/2030

CPD Number: ELE-M-17 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00046-00001	DoubleI / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.036(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.40	0.23	0.37	51
	00046-00002	DoubleI / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.036(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.40	0.23	0.37	51
	00047-00001	PDE59B / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	N		CL	0.38	0.19	0.32	51
	00048-00001	PDE59B / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.40	0.17	0.27	51
	00048-00002	PDE59B / ARG / YEA-Lami (5mm| 060PVB|5mm) - 31mm IG	AT/AT	2	0.04(2), 0.147(3)	0.470	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.40	0.17	0.27	51

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATI	**09/06/2025**	2000mm x 2000mm	0.296	0.283	R9027.01-116-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: 